



VERTICAL – ABOVE SLAB CONSTRUCTION CHECKLIST

Royse City Fire Department - Fire Marshal's Office
305 N Arch St. • Royse City, TX 75189 • Phone: 972.524.4819
Website: <http://www.roysecity.com/departments/fire/>
Email: rcfd@roysecity.com

An inspection by the Royse City Fire Marshal's Office is required prior to commencing vertical construction

Please make sure the following minimum requirements are met prior to scheduling an inspection for **Approval for Vertical Construction**.

YES

- ❖ Fire lane pavement is installed, tested and approved for use _____
- ❖ Fire lane is stripped as per Royse City Fire Marshal's Office Signage Requirements Packet _____
- ❖ Site water lines are installed, tested and approved for use _____
- ❖ Fire hydrants are installed and ready for use _____
- ❖ Hydrants have 4 ½" x 5" Storz Hydrant Converter installed (prior to CO) _____
- ❖ 3' radius clearance around all hydrants _____

Fire apparatus access roads shall not be obstructed in any manner, including the parking of vehicles, whether attended or unattended for any period of time.

Call 972.524.4819 or 214.450.4095 to schedule inspection